

OFFICE OF CIVIL SURGEON, AMBALA



No/SSI/AMB/2023/164

Dated 16-06-2023

No objection Certificate (To whom it may concern)

Certified that the premises of Tulsi Public School, School No. 40316, Ambala City has been inspected by a team of Health Department office of Civil Surgeon, Ambala and the same has been found fit from sanitation and hygienic points of view.

Report of water bacteriological test is fit for human consumption.


Deputy Civil Surgeon (Health)
Ambala 

To
Principal,
Tulsi Public School,
School No. 40316, Ambala City.

From : The Chemist,
Public HealthEngg.Deptt.
Public HealthEngg. Water Testing Laboratory
Ambala Cantt.

To

Tulsi Public Sen.Sec.School
Hissar road , Ambala city

Memo No. 1260

Dt. 10/5/2023

Sub: Bact. Analysis of Water Sample

Ref. Your office Memo No. TPS/GEN/10 Dt. 08.05.2023 on the subject noted above.

This office is in receipt of one water sample for its bacteriological testing send by your office on the subject noted above.

The sample has been tested and the results are as under.

Sr. No.	Lab.No.	Name of the Source	No. of Coliform	Opinion
1	335	R.O Plant on Tubwell at Tulsi public sen.sec.school	NIL	Potable

Apes
10/5/2023

CHEMIST

TEST REPORT


Lab. ID. No. : AMB/00751/5/0408 Memo No: 1256 Report Issue Date: 10/05/2023
ISSUED TO : TULSI PUBLIC SEN.SEC.SCHOOL
HISSAR ROAD, AMBALA CITY
Sample Description & Type of analysis : Water (Chemical Analysis)
Customer Reference No.& Date : TPS/GEN/10 - 09.05.2023
Customer Name Who collected sample : PARSHANT Sample Quantity : 1 Lt.
Sample collected on dated : 09.05.2023 Date of Analysis started : 09.05.2023
Sample received on dated : 09.05.2023 Dated of analysis completed : 09.05.2023
Temperature : 26.7 °C Humidity : 68%RH
Source of Sample : R.O. PLANT ON TUBEWELL AT TULSI PUBLIC SEN. SEC. SCHOOL

RESULTS

S. No.	Parameter	Method Used	Results	IS: 10500:2012 (Second Revision)		Unit
				Desirable limit	Max. Permissible limit (in absence better alternate source)	
1	Total Dissolved Solid ^{180 °C}	APHA2540 C	118	500	2000	mg/l
2	Total Hardness	APHA2340 C	83.2	200	600	mg/l
3	Calcium (as Ca)	APHA3500-Ca	18.75	75	200	mg/l
4	Magnesium (as Mg)	APHA3500 Mg B	8.84	30	100	mg/l
5	Total Alkalinity CaCo ₃	APHA 2320 B	92.15	200	600	mg/l
6	Chloride (as Cl)	APHA 4500 Cl B	14.46	250	1000	mg/l
7	Fluoride (as F)	APHA 4500- F C	0.2	1.0	1.5	mg/l
8	pH @ 25 °C	APHA4500-H ⁺ B	7.12	6.5 to 8.5	No relaxation	pH Units
9	Nitrate (as NO ₃)	APHA4500-NO ₃ D	1	45	45	Mg/l

- I. The results given above are related to the sample as received and tested in PHED Lab, AmbalaCantt. Reliability of sample lies with the sender/collector.
- II. The test report can't be regenerated/re-produced in whole or in part without written permission of Laboratory.
- III. The test report can't be used for any publicity or any legal purpose.
- IV. The test samples meant for chemical analysis will be disposed off after 15 days from the date of issue of test report.
- V. Sample has not been collected by this lab

Sample analyzed by: Vikram (Water Analyst)


(Arpana Choudhary)
Authorized Signatory/Chemist
PHED Water Testing Laboratory,
Ambala cantt

---End of Report---

Govt. of Haryana
Public Health Engineering Department, Water Testing Laboratory Ambala Cantt. 133001
Email id: chemist.ambala@gmail.com

Test Report

Lab. ID. No. : AMB / 00751/05/0408


Memo No: 1256

Report Issue Date: 10/05/2023

RESULTS						
S. No.	Parameter	Method Used	Results	IS: 10500:2012 (Second Revision)		Unit
				Desirable limit	Max. Permissible limit (in absence better alternate source)	
1	Taste	IS:3025Part 8	Agreeable	Agreeable	Agreeable	-----
2	Odour	IS:3025Part 5	Agreeable	Agreeable	Agreeable	-----
3	Colour	APHA2120 B	<5	5 HU	15 HU	HU
4	Turbidity	APHA 2130 B	1.01	1 NTU	5 NTU	NTU
5	Iron as Fe	APHA 3500 Fe B	0.02	1.0	No Relaxation	mg/l
6	Sulphate (as SO ₄)	APHA 4500 So ₄	12	200	400	Mg/l

- I. The results given above are related to the sample as received and tested in PHED Lab, AmbalaCantt. Reliability of sample lies with the sender/collector.
- II. The test report can't be regenerated/re-produced in whole or in part without written permission of Laboratory.
- III. The test report can't be used for any publicity or any legal purpose.
- IV. The test samples meant for chemical analysis will be disposed off after 15 days from the date of issue of test report.
- V. Sample has not been collected by this lab

Sample analyzed by: Vikram (Water Analyst)



(Arpana Choudhary)
Authorized Signatory/Chemist
PHED Water Testing Laboratory,
Ambala Cantt.